



20 December 2024

Kevin Scarlett
Aquafit Limited
46 Andrew Baxter Drive
Airport Oaks 2022, Mangere
Auckland
ken@aquafit.co.nz

Dear Kevin

PRODUCT: Aquafit PVC manhole starter and finisher

APPROVAL TYPE: ACCEPTED PRODUCT RENEWAL

EFFECTIVE DATE: 20/12/2024

EXPIRY DATE: 20/12/2027

This letter confirms acceptance of the product subject to the provisions and definitions contained herein. The product will be listed on Watercare's product list according to the approval type.

As an accepted product it may be used for the specific function or operational area listed below but is not restrictive for exclusive use.

This product acceptance does not provide a guarantee of product procurement and does not infer or express acceptance of any conditions of quotation, sales or delivery.

1. The product description is:

Name	Manhole starter (inlet) and manhole finisher (outlet)
Model	
Configuration	Manhole adaptor made from uPVC pipe with adhesive, sand grit and hydrophilic seal
Special features	Hydrophilic seal

2. Manufacturing details:

Quality assurance	AS/NZS 1260: 2017 PVC-u Pipes and fittings for drain, waste and vent applications, Watermark License: WM74529 BEP-PVC 551: Best Environmental Practice - PVC
Factory and location	Mercer and Auckland, New Zealand
Third party /component supply	Pipe seals: Trelleborg Hydrotite hydrophilic seal: C.I. Takiron

3. Information to be supplied with product:

Technical installation and maintenance instructions, handling and (any) assembly directions to be readily available	
Other	-

4. Watercare Specification(s):

No.	Name	Version
MS	Materials Supply Standard	2.2

5. Limitations of acceptance:

Can be used at/for	Wastewater gravity networks
Cannot be used at/ for	-

Acceptance of this product shall automatically terminate:

- when the product design or material element is varied
- when the product fails to perform in service to the stated performance specification
- when the nature of the relevant Watercare specification is altered that results in product non-compliance
- when the quality assurance certification listed expires and is not renewed
- within three years of this letter

Watercare Services Limited reserves the right to review and revoke approvals at any time.

Regards,



Waldo Strydom

Principal Asset Lifecycle Engineer (Standards)
Watercare Services Limited