



20 December 2024

Kevin Scarlett
Aquafit Limited
46 Andrew Baxter Drive
Airport Oaks 2022, Mangere
Auckland
vern@aquafit.co.nz

Dear Kevin

PRODUCT: Heavy wall SN16 factory moulded junction and 45-degree bend

APPROVAL TYPE: ACCEPTED PRODUCT RENEWAL

EFFECTIVE DATE: 20/12/2024

EXPIRY DATE: 20/12/2027

This letter confirms acceptance of the product subject to the provisions and definitions contained herein. The product will be listed on Watercare's product list according to the approval type.

As an accepted product it may be used for the specific function or operational area listed below but is not restrictive for exclusive use.

This product acceptance does not provide a guarantee of product procurement and does not infer or express acceptance of any conditions of quotation, sales or delivery.

1. The product description is:

| | |
|-------------------------|--|
| Name | Heavy wall SN16 factory moulded junction and 45-degree bend |
| Model | - |
| Configuration | uPVC moulded body with Trelleborg Pressure Sealing Rings |
| Special features | Moulded Construction and support gusset provides extra strength, Reduced cutting, welding, and fibreglass during construction |

2. Manufacturing details:

| | |
|--------------------------------------|---|
| Quality assurance | AS/NZS 1260: 2017 PVC-u Pipes and fittings for drain, waste and vent applications, Watermark License: WM74529 BEP-PVC 551: Best Environmental Practice - PVC |
| Certification Body | ApprovalMark International Pty Ltd (Expiry Date: 14/08/2023) |
| Factory and location | Kimikimi Road, Mercer, New Zealand |
| Third party /component supply | Pipe seals: Trellebrog |

3. Information to be supplied with product:

| | |
|--|---|
| Technical installation and maintenance instructions, handling and (any) assembly directions to be readily available | |
| Other | - |



4. Watercare Specification(s):

| No. | Name | Version |
|-----|---------------------------|---------|
| MS | Materials Supply Standard | 2.2 |

5. Limitations of acceptance:

| | |
|-------------------------------|-----------------------------|
| Can be used at/for | Wastewater gravity networks |
| Cannot be used at/ for | - |

6. Product illustration:

| | |
|--------------------------------------|---|
| SN16 factory moulded junction |  |
| 45-degree spigot socket bend |  |

Acceptance of this product shall automatically terminate:

- when the product design or material element is varied
- when the product fails to perform in service to the stated performance specification
- when the nature of the relevant Watercare specification is altered that results in product non-compliance
- when the quality assurance certification listed expires and is not renewed
- within three years of this letter

Watercare Services Limited reserves the right to review and revoke approvals at any time.

Regard,



Waldo Strydom

Principal Asset Lifecycle Engineer (Standards)
Watercare Services Limited